

Note(1) *1 FM_{I2} is equipped with only for FDEJ71HKXE2B,112HKXE2B,140HKXE2B.

Color mark

Mark	Color	Mark	Color
BK	Black	**RD**	Red
BL	Blue	**WH**	White
BR	Brown	**Y**	Yellow
GR	Gray	**Y/GN**	Yellow/Green
OR	Orange		

Meaning of marks

Mark	Parts name	Mark	Parts name	Mark	Parts name
$FM_{I1,2}$	Fan motor	**ThI-R**	Thermistor	**CnA-Z**	Connector (□ mark)
$CF_{I1,2}$	Capacitor for FM_I	**SW1**	Indoor unit address ten's place	**TB**	Terminal block
$49F_I$	Internal thermostat for FM_I	**SW2**	Indoor unit address unit's place	**◁mark**	Terminal (F)
LM	Louver motor	**SW3**	Outdoor unit address ten's place	**■ mark**	Connector
LS	Limit switch	**SW4**	Outdoor unit address unit's place	**XR1**	Operation indication (DC12)
SM	Stepping motor (For Exp.v)	**SW6**	Change of heat pume type	**XR2**	Heating indication (DC12)
X1,2,3	Auxiliary relay (For FM_I)	**Trl**	Transformer	**XR3**	ON indication for CM (DC12)
X5	Auxiliary relay (For LM)	**Val**	Varistor	**XR4**	Check indication (DC12)
ThI-A	Thermistor	**LED·R**	Indication lamp (Red)	**XR5**	Distant operation
		LED·G	Indication lamp (Green)	**SK**	Spark killer
		F	Fuse		

Function of switches

Mark	Function		
SW5-1	ON	Input signal	Reverse Invalid
	OFF		Run Stop
SW5-2	ON	Heating temp. shift + 3°C	
	OFF	Normal	
SW5-3	ON	Test run of condensate pump motor	
	OFF	Normal	